

## Requirements for Temporary Distribution Boxes and Secondary Distribution Boxes



### Overview

Complete Guide: Construction Site Temporary Distribution Box What Is a Temporary Distribution Box?

A temporary distribution box, also referred to as a port.

### Key Takeaways

Temporary and secondary distribution boxes must ensure safe power distribution with proper circuit protection, weatherproof enclosures, and compliance with international electrical standards.

#### 1. Electrical Protection

- **Residual Current Devices (RCDs/GFCIs):** High-sensitivity 30 mA RCDs are mandatory to protect personnel from electric shocks, especially in wet or outdoor environments, by detecting leakage currents and disconnecting power within milliseconds .
- **Circuit Breakers:** Miniature Circuit Breakers (MCBs) protect low-current circuits, while Molded Case Circuit Breakers (MCCBs) handle high-current loads, automatically disconnecting power during overloads or short circuits .
- **Overcurrent Protection:** Each outgoing circuit must have appropriate overcurrent protection to prevent equipment damage and fire hazards .

#### 2. Enclosure and Environmental Protection

- Ingress Protection (IP) Ratings: Enclosures must be weatherproof, with IP44 suitable for general outdoor use and IP67 for fully exposed or wet conditions .
  - Robust Materials: Boxes should be made from corrosion-resistant materials such as GRP, stainless steel, or copper-free aluminum for durability in harsh environments .
  - Mechanical Protection: Enclosures must withstand rough handling, repeated plug cycles, and potential impacts on construction or event sites .
- ### 3. Standard Compliance
- IEC 60309: Industrial plugs and sockets for safe connection of equipment .
  - EN 61439: Low-voltage switchgear and controlgear assembly standards for safe distribution .
  - BS 7375 / BS 7671 Section 704: UK-specific guidance for temporary electrical installations .
  - NFPA 70 / NEC Article 590: US standards for temporary power installations .
- ### 4. Design and Functionality
- Portability: Temporary boxes must be movable and easy to deploy on-site, with pluggable or modular components for rapid assembly and dismantling .
  - Circuit Identification: Clear labeling of incoming and outgoing circuits, phase allocation, and branch identification is essential for safe operation and maintenance .
  - Load Management: Secondary distribution boxes should balance loads symmetrically and allow for monitoring of energy consumption via multifunction meters if required .
  - Connector Systems: Use standardized connectors (e.g., gesis® MINI, CLASSIC, RST®) to ensure compatibility and safe connections .
- ### 5. Inspection and Maintenance
- Regular Testing: Quarterly Electrical Installation Condition Reports (EICR) or equivalent inspections are recommended to ensure ongoing safety .
  - Maintenance Access: Boxes should allow easy access for inspection, replacement of protective devices, and connection adjustments without compromising safety .
- ### 6. Application-Specific Considerations

- Outdoor Events: Use IP66-rated enclosures with suitable CEE interfaces for stages, audio, and vendor areas .
- Hazardous Environments: Explosion-proof or corrosion-resistant boxes are required in chemical, oil, or marine environments .
- Load Diversity: Consider different equipment types (lighting, audio, refrigeration) and their startup characteristics when designing branch circuits .

### Summary

Temporary and secondary distribution boxes are critical for safe, flexible, and reliable power distribution in temporary installations. Compliance with RCD protection, circuit breakers, IP-rated enclosures, IEC/EN standards, and proper load management ensures both personnel safety and equipment protection. Proper design, labeling, and regular inspection further enhance operational safety and efficiency on construction sites, events, or industrial projects .

## Article Content

### METHODS AND REQUIREMENTS FOR INSTALLING NON

Splice boxes between the customer panel,with existing DB or CIC cable, and PG&E secondary distribution system are not allowed.

## Contact Us

Continue your research online:

Website: <https://coetzerinvestments.co.za>

Technical inquiry: <https://coetzerinvestments.co.za/contact.html>

This document is for preliminary research. Verify specifications against current standards, product documentation and project requirements.

